	Office	: 37, North Veli Street,
MUTHU. S. B.E., M.Sc., (Structs) F.I.E.,		MADURAI-625 001.
F.I.V., F.I.I.R.A., I		Phone : 0452-2340744
Chartered Engineer Regn. No. : F-0172533		Cell : 98421-70744
Registered Architect Regn. No. : CA/75/1479		E-mail : ermuthusivam@gmail.com
Valuer of Wealth Tax & Income Tax	Residence	: 24/13, Dr. Thangaraj Salai,
Government of India, Regn.No.C1/64 of 1988	Associate :	Vinayaga Nagar, Madurai-20.
Panel Valuer of L.I.C. of India	Er. M. Ashokkumar B.E., M.E., M.I.E., F.I.V.,	Phone: 0452-2529021

STATEMENT ACCOMPANYING FORM-"A"

1.	C	Door No. of the Building	:	R.S.No.146/1,2,3A & 4 at K.Puliankulam, Chekkanoorani, Madurai.
2.	N	ocation : Street/Ward No. ame of the Place,i.e., Corporation/ unicipality/Panchayat Union/ own ship/Contonment	: .	KEREN PUBLIC SCHOOL in R.S.No.146/1,2, 3A & 4 at Madurai Theni Main Road, K.Puliankulam, Chekkanoorani, Thirumangalam Taluk, Madurai District.
3.	Y	ear of construction	:	Main building G.F., F.F. & S.F. – 2009. Third floor – 2010. Annexure Building G.F., F.F. & S.F. – 20010.
4.		pproximate cost of construction s per Current rates	:	Rs.2,25,00,000/-
5.		urpose for which the building is eing used or proposed to be used	:	EDUCATION.
6.		urpose for which the building has in herto been used.	:	EDUCATION
7.	bı fo	etails of construction of the uilding (Particulars of the undation soil, Specification the Various parts under).	:	
	a)		:	R.C.C. footing foundation along with R.C.C. Pillars.
	b)	Basement	:	Brick work in Cement along with R.C.C. Pillars.
	c)	Superstructures	:	Brick work in Cement.
	d)	Floor and roof are to be given	:	Marble flooring and R.C.C Roofing.
8.Peri	od f	or which the license is required	:	18.04.2021 to 17.04.2024 (3 years).
9.No.o	f pe	ersons to be accommodated	:	2000 Nos.

9.(a) "CERTIFIED" that no addition or alteration has been made to be existing or portion of a building for which this application has been made, I undertake to obtain a fresh license in case any addition or alteration is made to the existing or portion of building, I also undertake to obtain a fresh license if the purpose for which the license was granted for the use of building or a portion of the building originally is changed or altered subsequently".

03/02/21 SIGNATURE OF THE ENGINEER. MUTHU.S., B.E., M.Sc., (Structs), F.I.E., F.I.V., F.I.I.R.A., I.I.T.A., Chartered Engineer & Registered Architect Valuer of Wealth Taxand Income Tax Government of India 37, North Veli Street, Madurai-625004. Cell: 98421 70744

14

	Office	: 37, North Veli Street,
MUTHU. S. B.E., M.Sc., (Structs)	F.I.E.,	MADURAI-625 001.
F.I.V., F.I.I.R.A., I		Phone : 0452-2340744 Cell : 98421-70744
Chartered Engineer Regn. No. : F-0172533 Registered Architect Regn. No. : CA/75/1479		E-mail : ermuthusivam@gmail.com
Valuer of Wealth Tax & Income Tax	Residence	e: 24/13, Dr. Thangaraj Salai,
Government of India, Regn.No.C1/64 of 1988	Associate :	Vinayaga Nagar, Madurai-20.
Panel Valuer of L.I.C. of India	Er. M. Ashokkumar B.E., M.E., M.I.E., F.I.V.,	Phone : 0452-2529021

"FORM -B"

FOUNDATION.

2.

FORM of Certificate of structural soundness under sub-section 4 of the Tamilnadu Public building (Licencing) Act 1965 (Tamilnadu Public Buildings (Licencing) Rules 1966.

I Certify that I have inspected the building mentioned in the Statement and furnished below the salient technical features.

•	FOUNDATION.		
	a) Depth below ground level	:	10'0" or 3.05 Meter.
	b) Nature of soil met with at foundation	:	Gravel.
	c) Pressure at foundation	:	Main Building 43.44 M.T./Sqm.
			Annexure Building 33.67M.T/Sqm.
	d) Probable safe bearing capacity of		
	the Strata met with foundation	:	45 M.T./Sqm.
	SUPERSTRUCTURES:		
	a) Maximum stress in the most critical	:	Brick work in Cement 6.70 M.T./Sqm.
	Section of masonry and concrete.		Cement Concrete 43.44 M.T./Sqm for
			main building.
			33.67M.T/Sqm for Annexure Building.
	b) Nature of masonry and concrete and		Brick work in Cement 87 M.T./Sqm.
	Its safe permissible stress	:	Cement Concrete 109 M.T./Sqm.

The Structural soundness of the building has been verified by me with reference to ISI loading Standard 875 (Latest version) and other relevant is code of practice and I declare that the Building is structurally sound to be used as public building for the purpose noted in the Statement. A Licence may be granted for the period from 18.04.2021 to 17.04.2024 (3 years) inclusive.

SIGNATURE OF PHEENGINEER. MUTHU.S., B.E., M.Sc., (Structs)., F.I.E., F.I.V., F.I.I.R.A., I.I.T.A., Chartered Engineer & Registered Architect

Valuer of Wealth Taxand Income Tax Government of India

FORM ---- "C"

FORM of opinion under Sub-section I of Section 5 of the Tamilnadu Rubbic Survey (Licencing) Act 1965 (Tamilnadu XIII of 1965) referred to in Rule 5 of the Tamil Nadu persite Sullarings (Licencing) Rules 1966.

I have inspected the building specified in the statement below, and I have satisfied myself that the building is structurally sound to be used as a public buildings, for the Purposed noted in the statement, the structural-soundness of the building has been verified, taking into account, the Loading as per the latest Indian standards 875, I am therefore of the opinion, that a licence may be granted for the Period 18.04.2021 to 17.04.2024 (3 years) inclusive.

SIGNATURE OF THE ENGINEER MUTHU.S., B.E. M.Sc., (Structs), F.I.E., F.I.V., F.I.L.R.A., I.H.T.A., Chartered Engineer & Registered Architect Valuer of Wealth Taxand Income Tax Government of India 37, North Veli Street, Madurai-625 001, Cell: 98421 70744

ence : 24/13, Dr. Thangaraj Salai, Vinayaga Nagar, Madurai-20.
ence : 24/13, Dr. Thangaraj Salai,
CALLO D THE COLOR
E-mail . emidtilusivam@gmail.com
Cell : 98421-70744 E-mail : ermuthusivam@gmail.com
Phone : 0452-2340744
MADURAI-625 001.

STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the building, Door. No., Street, and Name of the Place.	KEREN PUBLIC SCHOOL in R.S.No.146/1,2,3A & 4 at Madurai Theni Main Road, K.Puliankulam, Chekkanoorani, Thirumangalam Taluk, Madurai District.	
No. & age of the building.	Main Building G.F.,F.F. & S.F. – 2009- 11 years. Third floor : 2010 – 10 years. Annexure Building G.F.,F.F. & S.F. – 2010- 10 years	
Short description of the Structures.	R.C.C. Roofing, Brick Masonry walls, Marble flooring.	
Purpose for which the buildings is Certified for use.	EDUCATION.	
Period for which the building will be structurally sound.	18.04.2021 to 17.04.2024 (3 years).	
No. of persons to be accommodated.	2000 Nos.	
REMARKS : BUILDING IS STRUCTURALLY SAFE STABILITY SHOULD BE CHECKED U YEARS.		

SIGNATURE OF THE ENGINEER. MUTHU.S., B.E. M.Sc., (Structs). 9

F.I.E., F.I.V., F.I.I.R.A., I.I.T.A., Chartered Engineer & Registered Architect

Valuer of Wealth Taxand Income Tax Government of India

DECLARATION

:

1

2

I.S.MUTHU, Son of Sevan. residing at 13,Dr.Thangaraj Sala 22,0, Whayaga Nagar, Madurai –20 (Residence), 37, North Veli Street, Madurai –01 (Office) do hereby declare that i possess the Qualification and experience specified in the Table to Rule II of the Tamilnadu Public Buildings(Licensing) Rules 1966 for issuing of the Certificate of Structural soundness of the buildings covered by the certificate.



Chartered Engineer & Registered Architect Valuer of Wealth Taxand Income Tax Government of India

1. Name & Address

2. Engineering Qualification

3. No. of years of Experience there of & Nature S.MUTHU .B.E. M.Sch Structural, F.I.E. Madurai-625 001. F.I.I.R.A, I.I.T.A., 37, North Vell Street, Madurai-625001.

Degree holder in Bachelor of Engineering (Madras University) 1964 B.E., M.Sc.(Structural Engineering) Madras University –1966. Member in the Institutions of Chartered Engineers and Institution of Valuers and Registered Indian Architects & Arbitrator. 50 Years of Experience in Chartered Engineering and consulting Architects. Valuer of Wealth Tax

and Income Tax Govt. of India, Panel Valuer of

L.I.C. of India.

SIGNATURE OF THE ENGINEER: Chartered Engineer & Registered Architect Valuer of Wealth Taxand Income Tax Government of India 37, North Veli Street. Madurai-625 00%.